



TYPE APPROVAL CERTIFICATE

Certificate No:
TAF000006R
Revision No:
1

This is to certify:

That the Horizontal Class A Division

with type designation(s)

A-15 Steel Deck - FireMaster Marine Plus Blanket 15 mm x 64 kg/m3

Issued to

Thermal Ceramics UK Ltd
Wirral, Merseyside, United Kingdom

is found to comply with

DNV GL statutory interpretations DNVGL-SI-0364 – SOLAS interpretations
DNV GL rules for classification – Ships
DNV GL offshore standards

Application :

Approved for use as a horizontal fire retarding division of class A-15.

This certificate is recognized by Transport Canada.

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Issued at **Høvik** on **2021-06-04**

for **DNV**

This Certificate is valid until **2026-06-03**.

DNV local station: **Manchester**

Approval Engineer: **Helge Bjørnarå**

Sverre Olav Bergli
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

A-15 Steel Deck - FireMaster Marine Plus Blanket 15 mm x 64 kg/m³, composed of a structural steel deck insulated on the exposed side (underside deck) with a single layer of 15 mm thick FireMaster Marine Plus Blanket (manufactured by Thermal Ceramics with density 64 kg/m³) applied across the tops of stiffeners following their contours.

The nominal blanket width is 610 mm and is to be compressed to a width of 600 mm to ensure compression at joints.

The blankets are held in place using copper coated steel pins (Ø 3 mm / typically 60 mm long) welded to the bulkhead and 38 mm friction-fit washers. The pins are to be installed with a nominal spacing of 200 mm across the blankets and maximum 350 mm along the blankets, whereas pins at the joints between blankets shall have a nominal spacing of 100 mm from the blanket edge.

The installation is to be performed according to the manufacturers Fire Protection Systems Information, reference No. FM MS 01 PW and No. FM 4.97.

The products may be manufactured at the premises of:

- Morgan Kailong (Jingmen) Thermal Ceramics Co., Ltd., Jingmen, China.
- Morgan Thermal Ceramics (Shanghai) Co., Ltd., Shanghai, China.
- Thermal Ceramics de France S.A., Saint-Marcellin-en-Forez, France.
- Murugappa Morgan Thermal Ceramics Ltd., Dist.- Gandhinagar, India.
- Murugappa Morgan Thermal Ceramics Ltd, Ranipet, India.
- Morgan Thermal Ceramics Korea, Daegu, Korea.
- Grupo Industrial Morgan SA de CV, Mineral de La Reforma, Mexico.
- Morgan Advanced Materials Industries Ltd, Abudhabi, United Arab Emirates.
- Thermal Ceramics, Inc., Augusta, USA.

Application/Limitation

Approved for use as a horizontal fire retarding division of class A-15.

Any surface materials used have to be approved for smoke and toxicity and low flame-spread characteristics (IMO 2010 FTP Code Parts 2 and 5) when required according to relevant rules.

Each product is to be supplied with its manual for installation and maintenance.

Type Approval documentation

Certification in accordance with Class Programme DNVGL-CP-0338, September 2018.

Test report No. FT10190 dated 28 May 2010 from Far East Fire Testing Centre, Shanghai, China.

Thermal Ceramics Fire Protection Systems Information, reference No. FM MS 01 PW and No. FM 4.97, Rev. 1.

Tests carried out

Tested according to IMO FTP Code Part 3 and in compliance with IMO 2010 FTP Code Ch.8.

Marking of product

The product or packing is to be marked with name of manufacturer, type designation and fire technical rating.

Transport Canada Approval

Based on the procedures laid down in the Transport Canada Publication entitled "Approval Procedures for, Life Saving Equipment and Structural Fire Protection Products (TP 14612)", DNV confirms that the product/s listed in this certificate is/are in accordance with Transport Canada's requirements

Periodical assessment

DNV's surveyor is to be given permission to perform Periodical Assessments at any time during the validity of this certificate and at least every second year. The arrangement is to be in accordance with procedure described in Class Programme DNVGL-CP-0338, Section 4.