

# TYPE APPROVAL CERTIFICATE

Certificate No: **TAF00000YD** Revision No: **1** 

This is to certify: That the Class H Fire Wall and Bulkhead

with type designation(s) H-0 Steel Bulkhead - 40 mm FireMaster Marine Plus Blanket

## Issued to Thermal Ceramics UK Ltd Wirral, Merseyside, United Kingdom

is found to comply with DNV offshore standards

# Application :

Approved for use as a vertical fire retarding division of class H-0.

Restricted application: Fire hazard from the insulated side only

Issued at Høvik on 2023-05-10

This Certificate is valid until **2028-05-09**. DNV local unit: **UK & Ireland CMC & VMC** 

Approval Engineer: Helge Bjørnarå

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



for **DNV** 

Jowita Permoda Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Job Id: Certificate No: Revision No:

262.1-005937-30 TAF00000YD 1

#### **Product description**

H-0 Steel Bulkhead - 40 mm FireMaster Marine Plus Blanket,

composed of a structural steel bulkhead insulated with a single layer of 40 mm thick FireMaster Marine Plus Blanket (manufactured by Thermal Ceramics with density 70 kg/m<sup>3</sup>) applied across the tops of stiffeners following their contours.

Total insulation thickness 40 mm.

The nominal blanket width is 610 mm and is to be compressed to a width of 580 mm to ensure compression at joints.

The blankets are held in place using steel pins ( $\emptyset$  3 mm / 12 to 25 mm longer than blanket thickness) welded to the bulkhead and friction-fit steel washers. The pins are to be installed with a nominal spacing of 300 mm in vertical direction and maximum 350 mm in horizontal direction, whereas pins at the joints shall have a nominal spacing of 100 mm.

The installation is to be performed according to the manufacturers Fire Protection Systems Information, reference No. FM MS 01 PW and No. FM 4.92.

The products may be manufactured at the premises of:

- Morgan Kailong (Jingmen) Thermal Ceramics Co., Ltd., Jingmen, China
- Morgan Thermal Ceramics (Shanghai) Co., Ltd., Shanghai, China
- Thermal Ceramics de France S.A., Saint Marcelin en Forez, France
- Murugappa Morgan Thermal Ceramics Ltd., Gujarat, India
- Murugappa Morgan Thermal Ceramics, Ranipet, India
- Thermal Ceramics Korea, Daegu, Korea
- Grupo Industrial Morgan SA de CV, Pachuca de Soto, Mexico
- Morgan Advanced Materials Industries Ltd, Abu Dhabi, United Arab Emirates
- Thermal Ceramics, Augusta, United States

### **Application/Limitation**

Approved for use as a fire retarding bulkhead of class H-0.

Restricted application: Fire hazard from the insulated side only

Each product is to be supplied with its manual for installation and maintenance.

#### Type Approval documentation

Certification in accordance with Class Programme DNV-CP-0338, September 2021.

Test report No. FT08150 dated 21 July 2008 from Far East Fire Testing Centre, Shanghai, China.

Thermal Ceramics Fire Protection Systems Information, reference No. FM MS 01 PW, Rev.9 and No. FM 4.92, Rev.1.

#### **Tests carried out**

Tested according to IMO FTP Code Part 3 (IMO Res. A.754(18)) with the hydrocarbon time-temperature curve specified in ISO 834-3.

#### Marking of product

The product or packing is to be marked with name of manufacturer, type designation and fire technical rating.

#### **Periodical assessment**

DNV's surveyor is to be given permission to perform Periodical Assessments at any time during the validity of this certificate and at least every second year. The arrangement is to be in accordance with procedure described in Class Programme DNV-CP-0338, Section 4.